

# Agenda Report

**TO:** CITY COUNCIL **DATE:** November 24, 2008  
**FROM:** CITY MANAGER  
**SUBJECT:** AMENDMENT TO CONTRACT NO. 19,575 WITH INSITUFORM TECHNOLOGIES INC., FOR 2008 RELINING OF CMP STORM DRAINS TO INCREASE THE TOTAL NOT TO EXCEED AMOUNT BY \$30,000 FROM \$175,000 TO \$205,000

## **RECOMMENDATION:**

It is recommended that the City Council amend Contract No. 19,575 with Insituform Technologies, Inc., to increase the contract by \$30,000 for a total not to exceed amount of \$205,000 for additional scope of work as part of the 2008 Relining of Corrugated Metal Pipe (CMP) Storm Drain project.

## **BACKGROUND:**

On April 21, 2008, Contract No. 19,575 was awarded to Insituform Technologies, Inc., for the subject project for a not to exceed amount of \$175,000. The scope of work includes the installation of pipe liners inside existing CMPs with diameters ranging from 12 to 18 inches, consisting of 800 lineal feet at three locations: 419 Bellmore Way, 1565 to 1575 Poppy Peak Drive, and 1220 Wynn Road to 1215 Sierra Madre Villa Avenue.

The initial contract award recommended a contingency of \$ 9,700. During the course of work, several existing voids were identified underneath the pipe at 1565 to 1575 Poppy Peak Drive and at 640 to 650 Busch Garden Lane that require filling prior to the installation of the pipe liner. An additional \$30,000 is needed to complete this work. The problem was identified through the video process and the repair method that was specified failed due to the steepness of the pipe and the size of the voids. Therefore, localized excavation at this location is necessary to complete rehabilitation of the subsequent sections of pipe. The

additional work includes excavation to fill the voids, replacement of portions of existing pipe, and the restoration of the existing private improvements.


The above described additional work can be completed within the \$30,000 requested under this contract amendment.

At the time of contract award, this project was acknowledged as being categorically exempt under Section 21084 of the California Environmental Quality Act of 1984 in accordance with Article 19, Section 15301 (Class 1), subsection (b) of the Resources Agency of California Guidelines (minor alternation of existing public facilities involving negligible or no expansion of use beyond that existing at the time of the lead agency's determination). This contract amendment requests additional funds to complete the original scope of work, and would be supported under the initial CEQA determination of categorically exempt.


**FISCAL IMPACT:**

Funds for this project are available in Capital Improvement Budget Account 76473, Preventative Maintenance – CMP Storm Drain.


Respectfully submitted,

  
\_\_\_\_\_  
MICHAEL J. BECK  
City Manager

Prepared by:

  
\_\_\_\_\_  
Steven L. Wright  
Assistant City Engineer  
Department of Public Works

Approved by:

  
\_\_\_\_\_  
Martin Pastucha, Director  
Department of Public Works