

DEPARTMENT OF PUBLIC WORKS

March 19, 2009

ADDENDUM NO. 2
ROBINSON PARK EXPANSION
IN THE CITY OF PASADENA, CALIFORNIA

TO: All Prospective Bidders

RE: Revisions to the Plans, Specifications, and Bidder's Proposal

Plans:

1. Sheet 4 of Drawing No. 5798: Construction Note No. 26 - "Install 15" HDPE Perforated Pipe" shall be deleted.
2. Sheet 19 of Drawing No. 5798: Detail No. 6, Backstop with Netting, is hereby revised, see attached.
3. Sheet 21 of Drawing No. 5798: Details Nos. 1, 2, 3, & 4 – The underlying base materials for the synthetic turf shall be changed from "*crushed miscellaneous base*" to "***permeable stone base***" as specified in Section II-23.01 of the Project Specifications.
4. Sheet 21A of Drawing No. 5798: The materials for all tubular steel fence, guard rails, and gates shall be changed from "5/8" sq. steel pickets" to "***3/4" sq. steel pickets, 14 gauge at 4-1/2" on center.***"

Specifications:

1. Section II-21.03 D.2a of the Project Specifications shall be changed from "*minimum 2" cover of organic mulch*" for all shrub and groundcover areas to "***minimum 3" cover of organic mulch.***"

Bidder's Proposal:

1. Page BP-3: Item No. 28 - 15" HDPE Perforated Pipe - shall be deleted.
2. Page BP-4: Item No. 59: The description shall be revised as follows: 4" Depth ***Permeable Stone Base***, Impervious Liner for Synthetic Turf, Perimeter Edge Details.

March 19, 2009

ADDENDUM NO. 2
ROBINSON PARK EXPANSION
IN THE CITY OF PASADENA, CALIFORNIA
(Continued)

3. Page BP-7: Item No. 132 - 3" Mulch: The quantity shall be changed from "960 C.Y." to "**60 C.Y.**"

Plans, Specifications, and Bidder's Proposal:

All references of HDPE Perforated and Non-perforated pipes on the Plans, Specifications, and Bidder's Proposal shall be changed to ***Double-wall Corrugated HPDE Storm Drain Pipe with the smooth inside wall by Advanced Drainage System (ADS) or approved equal. The pipe connections shall be bell and spigot per manufacturer's specifications.***


Attachments:

1. Revised Detail No. 6, Backstop with Netting, on Sheet 19 of Drawing No. 5798 per Addendum No. 2, dated March 19, 2009.
2. Revised Bidder's Proposal per Addendum No. 2, Pages BP-1 through BP-8, dated March 19, 2009. **THE REVISED BIDDER'S PROPOSAL DATED MARCH 19, 2009 SHALL BE USED FOR THE BID SUBMITTAL ON THIS PROJECT; FAILURE TO DO SO WILL RENDER THE CONTRACTOR'S BID NON-RESPONSIVE.**

Please indicate the notation "**Addenda Nos. 1 & 2**" on the "List of Addenda Received" on Page BP-8 of the revised Bidder's Proposal when submitting your bid. **FAILURE TO ACKNOWLEDGE RECEIPT OF ANY ADDENDA ISSUED WILL RENDER THE CONTRACTOR'S BID NON-RESPONSIVE.**

APPROVED:


DATE:



DANIEL A. RIX
City Engineer

for

3/19/2009



LEGEND

- ① POST CAP EYE-TYPE (TYPICAL ALL LINE POSTS)
- ② TOP RAIL
- ③ FENCE POST
- ④ CHAIN LINK FABRIC
- ⑤ MIDDLE RAIL
- ⑥ BOTTOM RAIL
- ⑦ 12" WIDE x 6" DEEP CONCRETE CURB. REFER TO DETAIL 1, SHEET 20.
- ⑧ 16" Ø X 0.312 STEEL POLE (ASTM A53 GRADE B) WITH WELDED ¼" CAP PLATE ON TOP.
- ⑨ 95% COMPACTED SUBGRADE PER GEOTECHNICAL REPORT.
- ⑩ CONCRETE FOOTING.
- ⑪ NOT USED
- ⑫ BRICK DUST. REFER TO CONSTRUCTION PLAN.
- ⑬ TREX COMPOSITE BACKBOARD. REFER TO DETAILS 1, 2, 3, 6 & 7, SHEET 20.
- ⑭ REDDEN SPORT NETTING #36 NYLON BASEBALL MESH, SEWN IN ROPE BORDER OR APPROVED EQUAL.
- ⑮ EXPANSION JOINT, SEE DETAIL 2, SHEET 17.
- ⑯ CONCRETE PAVING. REFER TO CONSTRUCTION PLAN.

NOTES

1. REFER TO FENCING SCHEDULE DETAIL 7, THIS SHEET FOR TOP RAILS, MIDDLE RAILS, BOTTOM RAILS, POSTS, FOOTINGS AND CHAINLINK FABRIC.
2. CONTRACTOR SHALL PROVIDE SHOP DRAWINGS OF BACKSTOP FENCING, FOOTING AND SPORT NETTING FOR APPROVAL PRIOR TO INSTALLATION.
3. CONTRACTOR SHALL PROVIDE SHOP DRAWING FOR ALL CONNECTIONS, HARDWARE, FASTENERS, CABLES, AND WELDS FOR APPROVAL PRIOR TO INSTALLATION.
4. ALL EXPOSED STEEL TO BE GALVANIZED FINISH.
5. EXCEPT AS INDICATED ON THE FENCING PLAN, SHEET 22, ALL OTHER SPORT NETTING STEEL POLE LOCATION SHALL BE EVENLY SPACED AT A DISTANCE NO GREATER THAT 50' O.C. CONTRACTOR SHALL PROVIDE DRAWING FOR POLE LOCATIONS FOR APPROVAL PRIOR TO INSTALLATION.

NOT TO SCALE

ADDENDUM #2
REVISED 3/19/09

BACKSTOP WITH NETTING

6

Revised per Addendum No. 2 – March 19, 2009

Bidder _____

Date _____

**BIDDER'S PROPOSAL
For the
ROBINSON PARK EXPANSION
IN THE
CITY OF PASADENA, CALIFORNIA**

Bid Opening: March 24, 2009, Office of the City Clerk, City Hall, 100 N. Garfield Avenue, Room S228, Pasadena, California

Michael J. Beck
City Manager
Pasadena, California

Dear Sir:

In response to Notice Inviting Bids dated February 4, 2009, for the Robinson Park Expansion in the City of Pasadena, California, the undersigned bidder proposes to furnish to the City of Pasadena all labor, materials, methods and processes, tools, implements and machinery which are necessary and required for the performance of the work mentioned in said Notice Inviting Bids in accordance with the Specifications therein referred to at the prices listed on pages BP-2 through BP-8 inclusive.

Each bidder must bid on each item shown in the Bidder's Proposal. If any bidder shall make any alteration, interlineation, or deviation in any of the printed matter of the proposal or if the signature of the bidder is incomplete, or if any portion of the Bid is incomplete, the bid will be considered informal and may be rejected.

The prices bid on the following items include any and all charges required under the California Retail Sales Tax Act of 1933, as amended, and/or the Use Tax of 1935 of said State.

In case of a discrepancy between the unit prices, and item totals, the unit prices shall prevail, and in case of a discrepancy between item totals and grand total, the item totals shall prevail. The grand total will be subject to adjustment by the City in the event of a discrepancy. The contract award shall be made on the basis of the grand total as described above from responsive and responsible bidders.

Based on the bid received and the City's budget at the time of contract award, the City reserves the right to delete items or to change quantities of bid items.

Revised per Addendum No. 2 – March 19, 2009

ROBINSON PARK EXPANSION
In the City of Pasadena, California

BIDDER'S PROPOSAL

Item No.	Item Description	Unit	Qty	UNIT PRICE (In Figures) Dollars Cents	ITEM TOTAL (In Figure) Dollars Cents
	MOBILIZATION				
1	Contractors Mobilization (Including permits, temporary services, and temporary fencing)	LS	100%		
2	Traffic Control	LS	100%		
	DEMOLITION				
3	Demolition and removal per plan and specifications.	LS	100%		
	ELECTRICAL & LIGHTING				
4	Single Head Parking Lot Lights	EA	7		
5	Post Top Walkway Light Fixtures	EA	7		
6	Sports Pole Lights	EA	10		
7	Gear Box	LS	100%		
8	Backfeed Community Center	LS	100%		
9	Pre-fab Building Connections	LS	100%		
10	Site Distribution Conduit, Conductors, Trench and Backfill	LS	100%		
	UTILITIES				
11	6" VCP Sewer	LF	276		
12	Clean-out	EA	2		
13	2" Domestic Water Line	LF	217		
14	2" Domestic Backflow	EA	1		
15	3/4" Copper	LF	826		
16	2" Shut Off Valve	EA	1		
17	3" ABS Drain Pipe	LF	87		
18	3/4" Shut Off Valve	EA	6		

Revised per Addendum No. 2 – March 19, 2009

**ROBINSON PARK EXPANSION
 BIDDER'S PROPOSAL – (Continued)**

Item No.	Item Description	Unit	Qty	UNIT PRICE (In Figures) Dollars Cents	ITEM TOTAL (In Figure) Dollars Cents
	GRADING AND EARTHWORK				
19	Cut material	CY	4,946		
20	Fill material	CY	14,398		
21	Import material	CY	9,452		
22	Fine grading	SF	38,060		
23	3' Overexcavation & Recompaction (at Bldg. Pads, Rtnng. Walls & 1' Overex. at AC Paving)	CY	2,090		
24	Erosion Control	LS	100%		
	DRAINAGE				
25	8" HDPE Corrugated Double Wall Perforated Pipe	LF	2,347		
26	10" HDPE Corrugated Double Wall Perforated Pipe	LF	407		
27	12" HDPE Corrugated Double Wall Perforated Pipe	LF	310		
28	15" HDPE Perforated Pipe	LF	54		
29	12" HDPE Corrugated Double Wall Pipe	LF	205		
30	15" HDPE Corrugated Double Wall Pipe	LF	570		
31	18" HDPE Corrugated Double Wall Pipe	LF	23		
32	Infield Multi-Flow Drainage System - Incl.'s Multi-Flow Piping, trenching, sand backfill	LF	5,500		
33	Infield Multi-Flow Drainage System - 8" PVC Drain line, trenching, gravel backfill	LF	290		
34	Infield Multi-Flow Drainage System - Cleanouts	EA	6		
35	Area Drain in Synthetic Turf	EA	10		
36	Area Drain (Modified) in Synthetic Turf	EA	5		
37	Cleanout in Synthetic Turf	EA	5		
38	Reinf. Conc. Retaining Wall Subdrain (incl.'s. Class 2 backfill & 4" Perf. Pipe)	LF	508		
39	CMU Retaining Wall Subdrain (incl. Class 2 backfill)	LF	535		
40	Infiltration Trench - Incl's trenching & gravel backfill	LF	280		
41	Infiltration Trench - Monitoring Observation Wells	EA	2		
42	Infiltration Trench - 3' Wide Curb Cut	EA	3		
43	18" RCP incl's trenching & backfill	LF	32		

Revised per Addendum No. 2 – March 19, 2009

ROBINSON PARK EXPANSION
 BIDDER'S PROPOSAL – (Continued)

Item No.	Item Description	Unit	Qty	UNIT PRICE (In Figures) Dollars Cents	ITEM TOTAL (In Figure) Dollars Cents
	DRAINAGE – (Continued)				
44	RCP Pipe Collar Connection to Exist. Catch Basin	EA	1		
45	10' Catch Basin	EA	1		
46	Local Depression	EA	1		
	PAVING, SURFACE MATERIAL, and CONSTRUCTION				
47	4" Thick PCC paving (Natural Grey)	SF	7,900		
48	4" Thick PCC with Sawcut Pattern	SF	990		
49	4" Thick AC Pavement	Ton	545		
50	4" Thick Aggregate Base	Ton	545		
51	4" Thick Integral Colored PCC	LF	9,250		
52	4" Thick by 12" Wide PCC Band	LF	130		
53	4" Depth Brick Dust at Infield	SF	39,000		
54	4" Thick Aggregate Base (at Bldg. Pad)	Ton	40		
55	Concrete Steps with 6" Riser	SF	525		
56	Concrete Ramp	SF	765		
57	1-1/2" Dia ADA Approved Handrails	LF	350		
58	Concrete Access Ramp	EA	6		
59	4" Depth Permeable Stone Base, Impervious Liner for Synthetic Turf, Perimeter Edge Details	SF	153,960		
60	Concrete Wheel Stops	EA	6		
61	4" White Striping (Parking)	LF	1,260		
62	Handicap Parking Symbol	EA	6		
63	Driveway Approach and Gutter and 1' Wide Restore AC Pavement	EA	3		
64	Paint Accessible Parking Striping	SF	576		
65	Construct "Type A1-150(6)" Curb	LF	700		
66	Construct "Type A2-150(6)" Curb and Gutter	LF	366		

Revised per Addendum No. 2 – March 19, 2009

**ROBINSON PARK EXPANSION
BIDDER'S PROPOSAL – (Continued)**

Item No.	Item Description	Unit	Qty	UNIT PRICE (In Figures)		ITEM TOTAL (In Figure)	
				Dollars	Cents	Dollars	Cents
	FENCING and WALLS						
67	4' high chainlink fence	LF	164				
68	4' high 5' wide pedestrian access gate	EA	2				
69	6' high chainlink fence	LF	153				
70	6' high Wrought Iron Fence	LF	325				
71	6' high 5' wide wrought iron gate	EA	2				
72	6' high 18' wide wrought iron double gate	EA	1				
73	8' high chainlink fence	LF	285				
74	8' high 5' wide pedestrian access gate	EA	5				
75	8' high 10'-0" wide double gate	EA	2				
76	10' high chainlink fence	LF	575				
77	10' high chainlink fence with 20' High nylon netting	LF	775				
78	10' high chainlink fence with 20' High nylon netting and hood	LF	90				
79	10' high 11'-6" wide maintenance double gate	EA	3				
80	10' High Batting Cage Fencing	LF	212				
81	10' High Bullpen Fencing	LF	180				
82	Batting Cage Gate	EA	4				
83	Bullpen Gate	EA	2				
84	Chainlink Dugout w/ Canopy 30'X10'	EA	4				
85	3'-0" CMU Retaining Wall	LF	130				
86	5'-0" CMU Retaining Wall	LF	65				
87	6'-8" CMU Retaining Wall	LF	95				
88	8'-0" CMU Retaining Wall	LF	130				
89	9'-0" CMU Retaining Wall	LF	115				
90	5' Reinf. Concrete Retaining Wall "A"	LF	108				
91	6' Reinf. Concrete Retaining Wall "B"	LF	115				
92	4' Reinf. Concrete Retaining Wall "C"	LF	155				

Revised per Addendum No. 2 – March 19, 2009

**ROBINSON PARK EXPANSION
 BIDDER'S PROPOSAL – (Continued)**

Item No.	Item Description	Unit	Qty	UNIT PRICE (In Figures) Dollars Cents	ITEM TOTAL (In Figure) Dollars Cents
	FENCING and WALLS – (Continued)				
93	4' Reinf. Concrete Retaining Wall "D"	LF	130		
94	30" Planter Wall (CMU)	LF	22		
95	30" Seat Wall (Reinf. Concrete)	LF	41		
96	CMU Trash Enclosure - Incl.'s Corr. Steel Deck Gate, Frame, Steel Posts, Latch, Conc. Slabs & Ftg's.	EA	1		
97	Reinf. Concrete Retaining Wall (APWA 601-2, Type 3)	LF	10		
	SITE AMENITIES				
98	Trash Receptacles and Lid	EA	11		
99	Bat Racks	EA	4		
100	Players Bench	EA	4		
101	Batting Cage & Bullpen Backstop Padding 4'x4'	EA	4		
102	Batting Cage & Bullpen Backstop Padding 4'x6'	EA	28		
103	Bullpen Netting (70'x10'x12' High)	EA	2		
104	Batting Cage Netting (50'x12'x12' High)	EA	2		
105	Batting Cage Home Plate	EA	2		
106	Premier Field Batting Cage/Bullpen 2x6 Trex Composite Back Stop	EA	4		
107	Bullpen Homeplate and Pitching Rubber	EA	2		
108	Infield bases Set, including pegs & pitching rubbers, home plate	EA	2		
109	Extra Base Anchors (set of 3)	EA	2		
110	Pre-cast Concrete Bench (Q2F072B)	EA	2		
111	Foul Poles	EA	2		
112	Water Misters	EA	5		
113	Precast Concrete Picnic Table (QR42FC)	EA	4		
114	Football Goal Post w/ sleeves (Pair)	EA	1		
115	Precast Accessible Picnic Table (QR42FC3)	EA	2		

Revised per Addendum No. 2 – March 19, 2009

ROBINSON PARK EXPANSION
 BIDDER'S PROPOSAL – (Continued)

Item No.	Item Description	Unit	Qty	UNIT PRICE (In Figures) Dollars Cents	ITEM TOTAL (In Figure) Dollars Cents
	SITE AMENITIES – (Continued)				
116	Removable Bollards	EA	2		
117	Root Barrier	LF	240		
118	6" Wide Concrete Mowcurb	LF	20		
119	Drinking Fountain	EA	1		
120	Baseball Scoreboard	EA	2		
121	Football Scoreboard	EA	1		
122	Ballfield Aluminum bleachers 21' long	EA	3		
123	Ballfield Aluminum bleachers 27' long	EA	2		
124	Football Aluminum bleachers	EA	1		
	PLANTING and IRRIGATION				
125	24" Box Tree	EA	40		
126	15 Gallon Shrub	EA	40		
127	5 Gallon Shrub	EA	63		
128	1 Gallon Shrub	EA	960		
129	Sod	SF	18,900		
130	No Mow Sod	SF	21,700		
131	Soil Preparation	SF	49,750		
132	3" Mulch	CY	60		
133	Irrigation System per plan, details, & specifications	LS	100%		
				Grand Total	

(Also enter total at top of BP-8)

Revised per Addendum No. 2 – March 19, 2009

TOTAL \$ _____

The undersigned bidder agrees to commence work within fifteen (15) calendar days from the date of issuance of a Notice to Proceed and proposes and agrees to have all work completed within one hundred twenty (120) working days after contract time commences.

The undersigned bidder acknowledged receipt of the following addenda issued for the above project. If no addenda have been received, write "none". FAILURE TO ACKNOWLEDGE RECEIPT OF ANY ADDENDA ISSUED WILL RENDER THE CONTRACTOR'S BID NON-RESPONSIVE.

List of Addenda Received: _____

PLEASE SEE PART I SECTION 2.01.3 REQUIRED FORMS.

Bidder shall execute the following (Appendix "A"):

	Page
1. Identity Confirmation	BP-(a)
2. Subcontractor Listing/ Shoring Design	BP-(b)
3. Affidavit of Non-Collusion	BP-(c)
4. Questionnaire	BP-(d)
5. Living Wage Compliance Certification	BP-(e)
6. Equal Opportunity Employment & Non0Segregation	AA FORMS

The Bidder declares that neither he nor any member of his firm or corporation is an officer or an employee of the City of Pasadena

Bidder's Proposal
Respectfully Submitted,

(If a Bidder is a corporation,
Its seal must be impressed hereon)

by _____
Authorized Signatory

California State Contractor's License No. _____

California Corporation No. _____