

# ATTACHMENT H PASADENA POWER DIVISION

## Check Sheet

TENTATIVE PARCEL MAP NO.: 61676  
DATE TENTATIVE MAP RECEIVED: JUNE 21, 2005  
LOCATION: 725 HILLSIDE TERRACE  
DATE CHECK OF TENTATIVE MAP AND ACCOMPANYING DATA COMPLETED: JULY 11,,2005

	YES	NO
The Water & Power, Power Delivery Unit can serve the area in accordance with the light & Power Rate Ordinance.	X	
Are underground installations specified?		X
Are easements required?		X

---

### REMARKS:

This proposed lot split for development will be served by the Pasadena Water and Power Department, Power Delivery Unit.

PARCEL, LOT 1.

This lot is presently fed electrically, from its own private electric vault facility.

PARCEL, LOT 2.

Power department is to install new 2-4"PVC, concrete encased, service conduits west from its electrical system located in Hillside Terrace, stubbing at the property line, as a cost to owner/developer. If future electric load requirements are greater than 200amps., the owner/developer will be required to install a new private property electric vault as per the department's Engineering and Utility Planners recommendations.

No bonds or certificates of deposit will be required for Power Department facilities.

SBC should be contacted for their requirements.



**RON SMITH**  
Principal Engineer